



# MARVEL Technology Review

## Thermal-hydraulic & Safety Basis

March 7, 2024

**Carlo Parisi, Ph.D.**

# Overview


- MARVEL Thermal-hydraulics
- Modeling
- Boundary Conditions and Assumptions
- Acceptance Criteria
- Uncertainties and Hot Channel Factors
- Deterministic Safety Analysis Results

# General Thermal-hydraulic Characteristics


- MARVEL general thermal-hydraulic (TH) characteristics** : liquid metal cooled, low-power density, closed loop, series-parallel coupled natural circulation system



MARVEL 3D CAD




Natural convection



MARVEL natural circulation scheme

# System Description

- **Key TH characteristics:**
  - Use of natural circulation on primary and secondary sides
    - No pumps
    - Better flow distribution
    - Higher reliability
    - Simplicity
  - 4 loops
  - Core power:  $85 \text{ kW}_{\text{th}}$
  - Low power densities (average values)
  - Core average NaK temperature at Hot Full Power (HFP):  $\sim 500 \text{ }^{\circ}\text{C}$
  - Operating pressure in the cover gas zone:  $\sim 3.2 \text{ atm}$



MARVEL x-z section

# System description


- Use of analytical models for preliminary system design and numerical code verification

$$\dot{m} = \left( \frac{2\beta_T Q g \Delta z_c}{\bar{c}_p R} \rho_0^2 \right)^{\frac{1}{3}}$$


- Elevation difference  $\Delta z_c$  between thermal centers: ~1.1 m
- Minimization of circuit pressure drops  $R$
- Predicted total NaK mass flow at Hot Full Power: ~ 1.5 kg/s

- Non-dimensional analysis
  - for deriving steady-state maps
  - thermal-hydraulic stability studies

$$Re_{ss} = C \left[ \frac{(Gr_m)_{\Delta z_c}}{N_G} \right]^r = 1.956 \left[ \frac{(Gr_m)_{\Delta z_c}}{4524} \right]^{0.3636} \quad [\text{turbulent flow}]$$



Steady state natural circulation for turbulent flow




Stability map





# Thermal-hydraulic Modeling & Simulation Tools

- Modeling and simulation (M&S) strategy for safety analysis
  - Use **best-estimate** nuclear safety codes and commercial codes with **extensive nuclear pedigree** and **well-proven reliability**
  - Perform independent **high-fidelity** calculations using commercial computational fluid-dynamic (CFD) codes for selected system, structure, components (SSCs) for design validation



# MARVEL Thermal-Hydraulic Design

- Use of INL's RELAP5-3D system thermal-hydraulic code as an M&S workhorse
- The RELAP series of codes have been developed at **INL** for over **50 years**
  - RELAP5-3D is the **flagship** of nuclear reactor system analysis tools → most widely used nuclear reactor accident analysis code
  - Development still ongoing (e.g., integration into INL's MOOSE framework)
  - Capability to model liquid metals systems
    - Several fluid properties libraries available
    - Specific correlations for liquid-metal heat transfer
    - 3-D hydraulic components, 3-D neutron kinetics
- TH model **validation** using MARVEL Integral Test Facility (ITF) **Primary Coolant Apparatus Test (PCAT)**




PCAT ITF




**MRP** Microreactor Program

# Boundary Conditions and Assumptions 1/2

- Core conditions from MCNP code Monte Carlo calculations
  - Core at Beginning of Life (BOL)
  - ANS-05 decay standard
  - Reactivity coefficients vs. temperature
  - Pin power peaking factors
  - Axial power peaking factor



Pin Radial Peaking Factors



Axial Peaking Factor



# Boundary Conditions and Assumptions 2/2

- Conservative assumptions for Beyond Extremely Unlikely events (BEU) → higher PCS and fuel temperatures
  - Gamma and neutron heating concentrated in the BeO
  - Other parameters


Parameters	Best-Estimate	Conservative
Overpower factor for the hot channel	1.0	1.15
Fuel heat transfer coefficient	Laminar/Turbulent	Laminar
Helium Stirling engine average temperature at HFP, °C	300	325

# Acceptance Criteria

- For Extremely Unlikely (EU) events, applied to Beyond Extremely Unlikely (BEU) events
  - Fuel: from fuel mechanics analysis
  - Clad: avoid localized boiling (surface temperature < NaK saturation temperature at atmospheric pressure)
  - Bulk coolant: protect PCS integrity
  - Core: qualitative, respected if criterion 2) achieved

## Acceptance Criteria

1	Peak fuel centerline temperature < 925 °C
2	Peak clad internal temperature < 764 °C
4	Bulk coolant < 704 °C
5	Core remains coolable



# Deterministic Analysis Options




- RELAP5-3D is a Best Estimate code (BE)
- Safety analysis strategy: using combination of options 2+3
- Conservative assumptions for systems availability, e.g.
  - No scram

Option	Computer code	Availability of systems	Initial and boundary conditions
1	Conservative	Conservative assumptions	Conservative input data
2	BE	Conservative assumptions	Conservative input data
3	BE	Conservative assumptions	Realistic input data with uncertainties
4	BE	Probabilistic safety analysis based assumptions	Realistic input data with uncertainties

Options for Safety analysis  
[from IAEA, SRS No. 52]

# Uncertainties & Hot Channel Factors

- Hot channel factors (HCF) implemented in RELAP5-3D as safeguards against **uncertainties** (minimize margins)
  - protect fission product barriers (fuel, clad, PCS)
- HCF derived from references based on past experiences, analytical models, qualified references, high fidelity calculations
- HCF to be updated
  - using PCAT data
  - before going critical



$$T_M = T_{in} + \sum_{m=1}^M F_m \Delta T_{m,nom}$$

Temperatures of Interest

# Uncertainties & Hot Channel Factors


- HCF treat in a conservative way (direct + statistical combination) uncertainties on:
  - Coolant mixing
  - Power & temperature measurements
  - Core heat transfer coefficient
  - Fuel geometry tolerances
  - Material physical properties (fuel, coolant, clad, gap)
  - Fuel nuclear properties
- Probabilistic treatment being considered for future uncertainty quantification (UQ) using RELAP5-3D/RAVEN code




# Normal Operation: Steady-State 1/2

- Steady State results for 36 TRIGA fuel rods, 1.414" OD (3.59 cm), 25" (63.5 cm) tall active core
- Reactor power: 85 KW<sub>th</sub>
- All structures in thermal equilibrium
- Good steady-state temperature margins


Parameters - Primary & secondary side	Values
NaK inlet core temperature, °C	471
NaK outlet core temperature, °C	540
NaK core temperature rise, °C	69
Total mass flow, kg/s	1.49
EGaInSn minimum temperature, °C	403
EGaInSn maximum temperature, °C	425
EGaInSn temperature rise, °C	22
IHX EGaInSn mass flow, kg/s	2.6



Temperature safety margins



Mass flows




Core inlet/outlet temperatures




# Normal Operation: Steady-State 2/2

- Other relevant parameters


Parameters	Values
PCS pressure drop, Pa	160
BeO side reflector maximum temperature, °C	519
PCS wall maximum temperature, °C	540
PCS primary pressure, kPa	307
Guard vessel to air heat losses, kW	4.8
Air riser nominal inlet temperature, °C	20
Air riser outlet temperature, °C	36



Fuel and NaK core temperatures 1/2



Fuel and NaK core temperatures 2/2




Air riser temperatures




# Normal Operation: Load Following

- **Load-follow:**


- Simulate reaction to imposed power change: 100/75/100 %  $P_{nom}$  over ~2.5 hr period
- All four Stirling engines in operation
- Control system simulate reactivity insertion by control drums
  - Reactivity insertion vs. position
  - Drum rotation speed
- Power changes imposed (simulate  $\pm 5\%$   $P_{nom}$ /min ramps)
  - PCS max temperature rate:  $\sim 0.91$  °C/min ( $\sim 54.5$  °C/hour)
  - CD reactivity rate:  $\sim \pm 1.4$  cents/min




Reactivity




PCS & guard vessel temperatures



Reactor power



System mass flows



Temperature safety margins




**MRP** Microreactor Program




# Postulated Accident Conditions: UTOP at HFP, w/ Stirling engines

- **Unprotected Transient Overpower**


- Step reactivity insertion (0.4\$) → 1 CD out from critical position to the mechanical stops
- No SCRAM
- Stirling engines on → maximize energy release to the fuel
- Reactor power peaks  $\sim 3.74 P_{\text{NOM}}$  (318 kW) at  $t = 12$  s
- Negative reactivity feedbacks counters the power surge → system back to a steady higher power and higher temperature by  $t = \sim 20$  min
- **No safety concerns** until scram (not needed)




Reactivity




PCS & guard vessel temperatures



Reactor power



Core mass flows




Temperature safety margins




**MRP** Microreactor Program

# Postulated Accident Conditions: UTOP at HFP, w/o Stirling engines


- **Unprotected Transient Overpower**
  - Step reactivity insertion (0.4\$) → 1 CD out from critical position to the mechanical stops
  - No SCRAM
  - Stirling engines off → maximize PCS temperature and pressure
  - Used for ASME D-section calculations
  - **No safety concerns until scram (not needed)**




Primary pressure comparison




PCS & guard vessel temperatures comparison



Reactor power



Clad safety margins




Fuel/coolant safety margins






# Postulated Accident Conditions: UTOP at CZP


- **Unprotected Transient Overpower at Cold Zero Power (20 °C)**
  - Step reactivity insertion (1.3\$) → 1 CD out from critical position to the mechanical stops
  - No SCRAM
  - Reactor power peaks  $\sim 34 P_{\text{NOM}}$  (2.9 MW) at  $t = 2$  s
  - Negative reactivity feedbacks counters the power surge
  - **No safety concerns** during first 5 minutes, reasonably also later
    - Temperatures stay safely low
  - Fast temperature ramp rate ( $\sim 11$  °C/min), but max PCS temperature  $< 200$  °C




Reactor power




Core mass flows



Reactivity



PCS & guard vessel temperatures




Temperature safety margins




# Postulated Accident Conditions: ULOHS


- **Unprotected Loss of Heat Sink**
  - All 4 Stirling engines heat removal lost at  $t = 1.0$  s
  - No SCRAM
  - Reactor cooled only by **heat losses** through guard vessel only (~4.8 kW) → conservative assumption
  - Reactor shutdown by intrinsic negative reactivity
  - Return to power caused by fuel cooldown
  - Core power < guard vessel heat losses for first 24 hr
  - **No safety concerns** during at least first 24 hr
  - Beyond 24 hr, reactor power = heat losses (new equilibrium)




Reactor power & heat losses




Core mass flowrate



Temperature safety margins



Reactivity




PCS & guard vessel temperatures




# Postulated Accident Conditions: ULOF

- **Unprotected Loss of Flow**


- Total blockage of all 4 downcomers at time  $t = 0.0$  s (assume catastrophic damage of all 4 IHXs) →
  - **not credible event**
  - bounding **partial loss of flow** events
- no SCRAM
- Loss of secondary side (IHX) heat removal capabilities
- Reactor cooled **only** by heat losses through guard vessel
- Reactor power self-reduced
- Hot spot clad temperature not of safety concern due to the reactor self shut-down features
- **No safety concerns** : data shown for the first 24 hrs, beyond that reactor power = heat losses (new equilibrium)




Reactor power & heat losses




Reactivity




Core mass flow



Hot spot temperature



PCS & guard vessel temperatures




Temperature safety margins






# Postulated Accident Conditions: ULOF, no DHRAC


- **Unprotected Loss of Flow and blockage of Decay Heat Removal Air Channel (DHRAC)**
  - Loss of secondary side (IHX) heat removal capabilities
  - Total loss of cooling
  - Reactor power self-reduced
  - Hot spot clad temperature not of safety concern due to the reactor self shut-down features
  - **No safety concerns** for the first 24 hrs




Reactor power & heat losses




Reactivity




Be and BeO temperatures



System pressures



PCS & guard vessel temperatures



Temperature safety margins



**MRP** Microreactor Program

# Postulated Accident Conditions: ULOCA


- **Unprotected Loss of Coolant Accident**
  - MARVEL reactor avoids by-design the NaK level drop below the top of the core (core never uncovered) also during the break of the low-elevation components (downcomer, lower plenum)
  - Decay heat removal capabilities bounded by ULOF calculations



# Summary

- RELAP5-3D system analysis shows reliable and stable MARVEL performances during operational transients and selected BEU transients
- **Very conservative** accident analysis shows that all **minimum safety margins are > 0**

Transient	Minimum margins (°C)		
	Clad	Fuel centerline	Bulk Coolant
UTOP- HFP	18	201	100
UTOP - CZP	470	620	505
ULOHS	118	291	125
ULOF	9	190	160



# **MRP** Microreactor Program

Questions?