



MARVEL Technology Review: Thermal Hydraulics and Safety Basis

October 19, 2022

Carlo Parisi, Ph.D.

Overview


- Thermal-Hydraulic Characteristics
- Modeling Tools
- Simulation Results
 - Steady State
 - Shutdown / Startup
 - Load Following
 - Beyond Design Basis Accidents
- Primary Coolant Apparatus Test (PCAT)

General Thermal-hydraulic characteristics


- MARVEL microreactor thermal-Hydraulic (TH) characteristics** : liquid-metal-cooled, low-power density, closed loop, series-parallel coupled natural circulation system



MARVEL 3D CAD



Natural circulation



MARVEL natural circulation scheme

Primary Loop Description

- **Key TH characteristics:**

- Use of natural circulation

- No pumps
 - Better flow distribution
 - Higher reliability
 - Simplicity

$$\dot{m} = \left(\frac{2\beta_T Q g \Delta H}{\bar{c}_p R} \rho_0^2 \right)^{\frac{1}{3}}$$

$$\Delta T_H = \left(\frac{R Q^2}{2\rho_0^2 \beta_T g \Delta H \bar{c}_p^2} \rho_0^2 \right)^{\frac{1}{3}}$$

- Four loops

- Core power: 85 kW_{th}

- Low power densities (average values):

- 14.3 kW/liter
 - 0.03 MW/m²
 - 3.72 kW/m


- Elevation difference between thermal centers: 1.13 m

- Minimization of circuit pressure drops

- Total NaK mass flow: ~ 1.55 kg/s

- Core average NaK temperature at hot full power (HFP): ~ 500°C

- Operating pressure in the cover gas zone: ~ 2.87 atm gauge




MARVEL x-z section



MRP Microreactor Program


Secondary Loop Description

- Key TH characteristics:
 - Four intermediate heat exchangers (IHX)
 - Removed power: $\sim 20 \text{ kW}_{\text{th}}$ each
 - Double head, annular section
 - Single double-wall thermally insulated downcomer
 - Elevation difference between thermal centers : $\sim 0.28 \text{ m}$
 - Minimization of circuit pressure drops
 - Pb mass flow: $\sim 5.2 \text{ kg/s}$
 - Average Pb temperature at HFP: $\sim 396^\circ\text{C}$



Thermal-hydraulic Modeling & Simulation Tools


- Modeling and simulation (M&S) strategy for safety analysis
 - Use **best-estimate** nuclear safety codes and commercial codes with **extensive nuclear pedigree** and **well-proven reliability**
 - Perform independent **high-fidelity** calculations using commercial computational fluid-dynamic (CFD) codes for selected system, structure, components (SSCs) for design validation
 - TH model validation using MARVEL Integral Test Facility (ITF) PCAT




Thermal-Hydraulic Modeling & Simulation Tools

- RELAP5-3D thermal-hydraulic and neutronic model for **steady-state & transient analysis**

- Includes primary & four secondary loops, guard vessel, shielding, air cooling riser
- Core components: single sub-channel + hot channel factors & four channels (different rings)
- Reactivity coefficients for 0D neutronic module
- Component materials (BeO, Be, C-steel, ZrH, etc.)
- Control & protection systems for power ramps and scram



Core 36-rods TH model



RELAP5-3D MARVEL model



MRP Microreactor Program

Design Limits

- Acceptance criteria based on
 - Fuel and coolant temperature
 - To be verified by RELAP5-3D
- Stress and strain in the clad verified by dedicated thermo-mechanical analysis by RELAP5-3D-BISON coupled calculations


Design Criteria	Design Basis Events			
	Normal Operation	Anticipated Events	Unlikely Events	Extremely Unlikely Events
1	Peak fuel centerline temperature < 700°C			
2		Peak fuel centerline temperature < 1050°C		
3	Bulk coolant < 650°C			
4	Peak clad internal temperature < 650°C			
5			Peak clad internal temperature < 704°C	Peak clad internal temperature < 704°C (long term), <788°C (short term)
6			Bulk coolant < 704°C	
7	Core remains coolable			

Hot Channel Factors


- Hot channel factors (HCF) implemented in RELAP5-3D as safeguards against **uncertainties** (minimize margins)
 - Protect fission product barriers (fuel, clad, PCS)
- HCF derived from references based on past experiences and sensitivity analysis
- HCF to be updated
 - Using data from ITF PCAT
 - Before going critical
- Probabilistic treatment being considered for future uncertainty quantification (UQ) using **RELAP5-3D** and **RAVEN** codes

Normal Operation: Steady-State

- Steady-state results for 36 TRIGA fuel rods, 1.414 in. OD (3.59 cm), 25 in. (63.5 cm) tall active core
- Reactor power: 85 KW_{th}
- All structures in thermal equilibrium
- Good steady-state temperature margins



Temperature safety margins



Air riser temperatures




MRP Microreactor Program


Parameters - Primary & Secondary Side	Values
NaK inlet core temperature, °C	465
NaK outlet core temperature, °C	532
NaK core temperature rise, °C	67
Total mass flow, kg/s	1.55
IHX Pb minimum temperature, °C	386
IHX Pb maximum temperature, °C	411
Pb temperature rise, °C	25
IHX Pb mass flow, kg/s	5.2

Normal Operation: Start-Up


- Tentative **start-up** sequence:
 - Heat the system above the Pb melting point ($T_{SYS} > 327.5^{\circ}\text{C}$)
 - System steady state at reactor power = 7 kW, $T_{avg} = 340^{\circ}\text{C}$
 - Perform power ascension to 85 kW in ~ 1 hr
 - 1.3 kW/minute
 - Max PCS temperature rates: $\sim 2.1^{\circ}\text{C}/\text{min}$
 - Control Drums (CDs) reactivity rate: ~ 1.3 cents/min
 - Stirling generators sink temperature adjusted after ~ 1 hr




Reactor power




Core, IHX and air riser mass flows



Reactivity



PCS & guard vessel temperatures




NaK temperatures




Normal Operation: Load-Follow

- **Load-follow:**


- Simulate reaction to imposed power change: 100/75/100% P_{nom} over ~2.5 hr period
- All four Stirling engines in operation
- Control system simulate reactivity insertion by control drums
 - Reactivity insertion vs. position
 - Drum rotation speed
- Assumption: “turbine follow” mode → Stirling engines react to remove power produced by the reactor
- Power changes imposed (simulate $\pm 5\% P_{nom}$ /min ramps)
 - PCS max temperature rate: $\sim 2.0^{\circ}\text{C}/\text{min}$
 - CD reactivity rate: $\sim \pm 1.4$ cents/min




Reactivity




PCS & guard vessel temperatures



Reactor power



Core mass flows




Temperature safety margins




MRP Microreactor Program

Normal Operation: Normal Shutdown


- Simulation of **Normal Shutdown**:
 - Reactor operating at HFP
 - Shutdown of four Stirling engines at t=60.0 sec
 - Decay heat removed via
 - Air riser (natural convection ~ 4.16 kWth)
 - Stirling engines (forced H₂O circulation and heat losses ~ 4 kWth total)
 - System cooldown characteristics
 - Max rate: ~ 1.63°C/min (98.7°C/hr)
 - Structures max temperature reaches ~300°C at t = +24 hr
 - Estimated time for hot standby condition (340°C): ~2.5 hr




Reactivity




PCS & guard vessel temperatures



Reactor power & heat losses



PCS and air riser mass flows




Stirling engines power




Start-Up & Shutdown


- Simulation of possible MARVEL operation during a weekend
- Start-up, operate for 24 hr, then shutdown




Reactor power




Stirling engines power



Core mass flows



Reactivity




PCS & guard vessel temperatures


Postulated Accident Conditions: UTOP at HFP

- **Unprotected Transient Overpower (UTOP)**


- Step reactivity insertion (0.4\$) → 1 CD out from critical position to the mechanical stops
- No scram
- Reactor power peaks ~4 P_{NOM} (340 kW) at t = 14 s
- Negative reactivity feedbacks counters the power surge → system back to a steady higher power and higher temperature by t = ~ 15 min
- **No safety concerns** until scram (not needed)




Reactor power




Core mass flows



Reactivity



PCS & guard vessel temperatures




Temperature safety margins




Postulated Accident Conditions: UTOP at CZP


- **Unprotected Transient Overpower at Cold Zero Power (CZP), 20°C**
 - Step reactivity insertion (1.3\$) → 1 CD out from critical position to the mechanical stops
 - No SCRAM
 - Reactor power peaks ~40 P_{NOM} (3.4 MW) at t = 2 s
 - Negative reactivity feedbacks counters the power surge
 - **No safety concerns** during first 5 minutes, reasonably also later
 - Temperatures stay safely low
 - Mechanical effects of fast temperature ramp rate being verified




Reactor power




Core mass flows



Temperature safety margins



Reactivity




PCS & guard vessel temperatures




Postulated Accident Conditions: ULOHS


- **Unprotected Loss of Heat Sink (ULOHS)**
 - All four Stirling engines heat removal lost at $t = 1.0$ s
 - No scram
 - Reactor cooled only by **heat losses** through guard vessel only (~4.1 kW) → conservative assumption
 - Reactor shutdown by intrinsic negative reactivity
 - Return to power caused by fuel cooldown
 - Core power < guard vessel heat losses for first 24 hr
 - **No safety concerns** during at least first 24 hr
 - Beyond 24 hr, reactor power = heat losses (new equilibrium)




Reactor power & heat losses




Core mass flowrate



Reactivity



PCS & guard vessel temperatures




Temperature safety margins




Postulated Accident Conditions: ULOF

- **Unprotected Loss of Flow (ULOF)**


- Total blockage of all 4 downcomers at time $t = 0.0$ s (assume catastrophic damage of all four IHXs) →
 - **Not credible event** (see structural mechanics presentation)
 - Bounding **partial loss of flow** events (intermediate design review comment)
- No scram
- Loss of secondary side (IHX) heat removal capabilities
- Reactor cooled **only** by heat losses through guard vessel
- Reactor power self-reduced
- Hot spot clad temperature not of safety concern due to the reactor self-shutdown features
- **No safety concerns** : data shown for the first 24 hr, beyond that reactor power = heat losses (new equilibrium)




Reactor power & heat losses




Reactivity




Core mass flow




Hot spot temperature



PCS & guard vessel temperatures



Temperature safety margins



Postulated Accident Conditions: ULOCA

- **Unprotected Loss of Coolant Accident (ULOCA)**
 - MARVEL reactor avoids by design the NaK level drop below the top of the core (core never uncovered) also during the break of the low-elevation components (downcomer, lower plenum)
 - Decay heat removal capabilities bounded by ULOF calculations


Summary of MARVEL Analysis

- RELAP5-3D system analysis shows reliable and stable MARVEL performances during start-up, normal operation and load following and shutdown
- **Very conservative** accident analysis shows that all **minimum safety margins are > 0**


Transient	Minimum Margins (°C)		
	Clad (short / long terms)	Fuel Centerline	Coolant Boiling
UTOP - HFP	121 / N/A	368	298
UTOP - CZP	394 / N/A	651	413
ULOHS	213 / 129	470	385
ULOF	134 / 50	395	300

PCAT General Thermal-Hydraulic Characteristics

- PCAT is the electrically-heated test loop of MARVEL
 - **Full scale** (1:1 elevation, power)
- General TH characteristics are similar to MARVEL : liquid-metal-cooled, low-power density, four closed loop, series-parallel coupled natural circulation system





PCAT 3D CAD



PCAT natural circulation scheme

Rationale for PCAT

- Capability of RELAP5-3D in modeling single-phase natural circulation well assessed by different projects and publications performed by several research institutions
 - PCAT RELAP5-3D analysis independently validated by high-fidelity tools (CFD analysis by S. Yoon, J. Kim) and first-principle independent calculations
- Rationale for PCAT:
 - Reduce the uncertainties in the modeling assumptions
 - Heat transfer coefficients (HTC) in core, IHX
 - Pressure drops at different Reynolds number
 - Heat losses at the Stirling engines
 - Combined systems dynamic (three coupled loops)
 - IHX performance
 - Stirling engines operation



PCAT CFD simulation



$$\Delta P_{fric} = \Delta P_{boyancy}$$

$$\frac{\beta g q_{co} L_{th}}{\rho_l a_c C_{pl} u_{co}^3} = \sum_{i=1}^N \left\{ \frac{1}{2} \left(\frac{f l}{d_h} + K \right)_i \left(\frac{a_c}{a_i} \right)^2 \right\}_o$$

Analytical model for natural circulation


Rationale for PCAT

- PCAT is heavily instrumented to allow **validation of the TH model** and **extrapolate MARVEL TH performances**
 - Three thermocouples (TC) per each heater
 - Three TC for core barrel
 - Three TC per loop
 - Fine temperature distribution measurement in the lower plenum
 - Five TC per IHX
 - One Flowmeter per loop
- PCAT in operation by beginning of calendar year 2023



Core heaters and TC





MRP Microreactor
Program