

MARVEL Documented Safety Analysis (DSA) Development Strategy and Results

Microreactor Program Review

March 2025





Doug Gerstner
Nuclear Safety Engineer
Idaho National Laboratory

PRESENTATION OVERVIEW

- MARVEL Design Overview
- PDSA Outline and Development Process
- Hazards Analyses Approach and Results
- Design Basis Accident Analysis Results
- Results/Conclusions

MARVEL Design Overview

Key Design Features	
Thermal Power	85 kW nominal
Weight	< 12 US ton
Primary Coolant	Sodium-Potassium eutectic (NaK)
Intermediate Coolant	NaK
Coolant Driver	Natural Convection, single phase
Fuel	TRIGA HALEU (UZrH), 304SS clad, end caps
Moderator	Hydrogen
Neutron Reflector	Graphite, Beryllium (S200), Beryllium oxide
Reactivity Control	Radial Control Drums, Central Absorber
Primary Coolant Boundary	SS316H



➤ Evolution of MARVEL from P-53 to current design. No PRA!

Safety-in-Design Regulatory Framework

- **10 CFR 830, Subpart B, Nuclear Safety Management**
 - Establishes the safety basis requirements for Department of Energy (DOE) nuclear facilities.
 - Requires the development of a documented safety analysis (DSA) to ensure that hazard controls are established to provide for the adequate protection of workers, the public, and the environment.
- **DOE O 420.1C, Facility Safety**
 - Establishes facility and programmatic requirements for:
 - Nuclear safety design criteria
 - Fire protection
 - Criticality safety
 - Natural phenomena hazards (NPH) mitigation
- **DOE-STD-1189-2016, Integration of Safety into the Design Process**

➤ **Process outlined in DOE-STD-1189-2016, “Integration of Safety Into the Design Process,” provides an opportunity to force a common understanding and agreement at key phases.**



NOT MEASUREMENT
SENSITIVE

DOE-STD-1189-2016
December 2016
Superseding
DOE-STD-1189-2008

DOE STANDARD INTEGRATION OF SAFETY INTO THE DESIGN PROCESS



U.S. Department of Energy
Washington, DC 20585



DISTRIBUTION STATEMENT A. Approved for public release; distribution is unlimited.



Early Integration of Safety Into the Design Process

- **Safety Design Strategy (SDS)** – Identification of Key Regulatory Requirements and Plant Safety Functions early to aid in guiding design.
 - *Submitted early and approved by DOE-Idaho (DOE-ID) to aid in guiding design.*
 - *SDS covers both dry criticality and full power ops.*
 - *Includes T-REXC.*
- **Preliminary Documented Safety Analysis (PDSA)** – Identification of detailed design parameters necessary to meet plant safety functions and confirmation that design meets general and specific design criteria.
 - *Submitted early and approved by DOE-ID to aid in guiding design.*
 - *Separate PDSA's for dry criticality and full power ops.*
- **Final DSA [Safety Analysis Report (SAR)] and Technical Specifications (TS)** – Documentation of as built configuration and confirmation it meets identified PSAR requirements.
 - *MARVEL PDSA and SAR are in the form of an addendum to the INL Transient Reactor Test (TREAT) safety analysis report (SAR)-420.*
 - *Separate FDSA's and TS's for dry criticality and full power ops*

➤ **DSA documents for compliance with 10 CFR 830 is progress.**





Key Safety Goals in the MARVEL Reactor Design

- **Technology choices drastically affect safety in design:**
 - Low thermal power and low burnup of fuel results in limited available source term.
 - Uranium-zirconium hydride fuel (U-ZrH), sodium-potassium eutectic (NaK) coolant, and structural materials are stable and compatible.
 - Low residual heat.
 - Arrangement of high-conductivity components ensures less stored energy and higher margin to softening or melting of components.
 - Near atmospheric operation of the reactor coolant system limits driving forces for release.
 - Safety functions, including the removal of decay heat, met without reliance on electrical power in response to a postulated event.
 - The reactor structure and other safety-related components are designed to withstand the safe shutdown earthquake.

Elements of Passive Safety Design Considered:

- Inherent negative reactivity feedback (IRF) ensures reactor power is controlled during overpower or overtemperature events.
- Decay heat removal during off-nominal events without the need for an emergency core cooling system.
- Multiple passive confinement barriers result in complicated release paths for fission product release.



MARVEL PDSA Format and Content

- Follows the existing 17-chapter format of TREAT FSAR as applicable and appropriate.
- Chapter 10 is replaced with a new “Interfacing Systems.”
 - Provides design and safety analysis requirements for End Users
- Content considers the following as guidance as appropriate for a DOE microreactor:
 - RG 1.70 (Used for TREAT FSAR. Being superseded by RG 1.206)
 - NUREG-0800
 - NUREG-1537
 - ANSI/ANS-15.21-2021
 - DOE-STD-1237
 - RG 1.232 (Design Criteria)

➤ **TREAT SAR and MARVEL PDSA in the form of a 17-chapter RG 1.70 (RG 1.206) SAR**


Idaho National Laboratory

MARVEL PRELIMINARY DOCUMENTED SAFETY ANALYSIS	Identifier:	SAR-420-ADD-1	
	Revision:	0	
	Effective Date:	DRAFT	Page: iv of x

CONTENTS

Section	Title	Rev.	Date
	Front Matter and Table of Contents	0	Draft
Chapter 1	Introduction and General Description of Facility	0	Draft
Chapter 2	Site Characteristics	0	Draft
Chapter 3	Design of Structures, Systems, and Components	0	Draft
Chapter 4	Reactor	0	Draft
Chapter 5	Reactor Coolant Systems	0	Draft
Chapter 6	Engineered Safety Features	0	Draft
Chapter 7	Instrumentation and Control Systems	0	Draft
Chapter 8	Electrical Power Systems	0	Draft
Chapter 9	Auxiliary Systems	0	Draft
Chapter 10	MARVEL Interfacing Systems	0	Draft
Chapter 11	Radiation Protection Program and Waste Management	0	Draft
Chapter 12	Radiation Protection	0	Draft
Chapter 13	Conduct of Operations	0	Draft
Chapter 14	Test Programs	0	Draft
Chapter 15	Accident Analyses	0	Draft
Chapter 16	Derivation of Technical Specifications	0	Draft
Chapter 17	Quality and Reliability Assurance	0	Draft

MARVEL PDSA Process






➤ *Process iterative over the MARVEL Reference, Interim, and final designs.*

MARVEL ECAR-6440 Hazard Evaluation Methodology

NEI-18-04, Risk-Informed Performance-Based Technology Inclusive Guidance for Non-Light Water Reactor Licensing Basis Development

MARVEL



Terminology:
 DSA=Documented Safety Analysis
 DBA=Design Basis Accident
 FSF=Fundamental Safety Function
 IRF=Inherent Reactivity Feedback
 SSC=Structure, System, Component
 SBE=Safety Basis Event
 SR=Safety-Related
 TOP=Transient Overpower
 TS=Technical Specifications

BNL-212380-2019-INRE

**Regulatory Review of Micro-Reactors –
Initial Considerations**

Manuscript Completed:
February 5, 2020

Prepared by:
Pranab Samanta, David Diamond, and John O'Hara
Nuclear Science and Technology Department
Brookhaven National Laboratory
Upton, NY 11973-5000

Prepared for:
Stewart Magruder and George Tartal
Office of Nuclear Reactor Regulation
U.S. Nuclear Regulatory Commission

SANDIA REPORT
SAND2020-4689
Printed April 2020

**Technical and Licensing
Considerations for Micro-Reactors**

Andrew Clark, Bradley A. Beeny, Kenneth C. Wagner, and David L. Luxat


Prepared by
Sandia National Laboratories
Albuquerque, New Mexico
87185 and Livermore,
California 94550

➤ **PRA not performed – MARVEL Hazard evaluation is largely qualitative.**

MARVEL Fundamental Safety Functions (FSFs)

MARVEL Safety Case:

- Low Power Output/Source Term/Decay Heat/Vessel Pressure
- Natural Coolant Circulation
- Multiple Fission Product Barriers
- Passive Heat Rejection to Ambient Air
- Passive Reactivity Control



➤ **Functions that if fulfilled, keep Initiating Events (IEs) from progressing to end states that could result in core damage and release of radioactive or hazardous material.**

Qualitative Event Sequence Analysis - TOP Example Only


Initiating Event	Reactivity Control			Heat Removal		Confinement		Event Sequence Identifier	End State		
	Is core power controlled through engineered means?	Is core power controlled through passive IRF?	Is core power controlled by operator manual scram?	Is core temperature controlled through engineered heat removal means?	Is core temperature controlled through passive heat removal means?	Is Fuel Cladding structural integrity lost?	Is PCB/GV integrity lost?				
Initiating Event	Core Power Controlled by RPS Trip and Control Drum Insertion			Core Temperature Controlled by Heat Extraction System		Confinement Barrier Structural Integrity Maintained		ES-1	No Radiological Release		
				Heat Extraction System Fails		Core Temperature Controlled by Passive Means		Confinement Barrier Structural Integrity Maintained		ES-2	No Radiological Release
						Passive Heat Removal Fails		Fuel Cladding Structural Integrity Lost	PCB/GV Structural Integrity Maintained	ES-3	Gaseous Fission Product Release
					PCB/GV Structural Integrity Lost			ES-4	Fission Product Release		
				Core Temperature Controlled by Heat Extraction System		Confinement Barrier Structural Integrity Maintained		ES-5	No Radiological Release		
	Core Power Controlled by Passive IRF			Heat Extraction System Fails		Core Temperature Controlled by Passive Means		Confinement Barrier Structural Integrity Maintained		ES-6	No Radiological Release
	Failure of RPS Trip and/or Control Drum Insertion					Passive Heat Removal Fails		Fuel Cladding Structural Integrity Lost	PCB/GV Structural Integrity Maintained	ES-7	Gaseous Fission Product Release
					PCB/GV Structural Integrity Lost			ES-8	Fission Product Release		
	Passive IRF Fails			Core Temperature Controlled by Heat Extraction System		Confinement Barrier Structural Integrity Maintained		ES-9	No Radiological Release		
				Heat Extraction System Fails		Core Temperature Controlled by Passive Means		Confinement Barrier Structural Integrity Maintained		ES-10	No Radiological Release
						Passive Heat Removal Fails		Fuel Cladding Structural Integrity Lost	PCB/GV Structural Integrity Maintained	ES-11	Gaseous Fission Product Release
		PCB/GV Structural Integrity Lost	ES-12	Fission Product Release							
	Manual Scram Fails			Core Temperature Not Controlled		Confinement Barrier Structural Integrity Lost		ES-13	Fission Product Release		

- **ES-6 relies on passive SSCs alone to perform the FSFs – Result is an end state with no core damage or rad release.**
- **Passive SSCs performing the Reactivity Control (IRF) and Heat Removal (Core SSCs providing conduction and convection to ultimate heat sink) are therefore designated as Safety-Related (SR).**
- **“Unprotected” ES-6 Frequency = (IE) x (Failure of Active Reactivity Control) x (Failure of Active Heat Removal)**

Qualitative Risk Analysis

- Based on DOE guidelines:
 - Probability of failure of an active FSF SSC is given a one qualitative frequency category frequency reduction (e.g., Anticipated to Unlikely).
 - Probability of failure of a passive FSF SSC is given a two qualitative frequency category frequency reduction (e.g., Anticipated to Extremely Unlikely).


- ***“Unprotected” TOP Frequency = (IE) x (Failure of Active Reactivity Control) x (Failure of Active Heat Removal) = Beyond Extremely Unlikely***
- ***TOP Qualitative evaluation assumes failure of Reactor Protection System trip and control drum insertion AND failure of active heat removal***
- ***TOP Relying solely on passive SR passive IRF and passive decay heat removal to ultimate heat sink***
- ***TOP qualitative risk analysis results in a risk bin IV, or “negligible” risk.***



Selection of Design Basis Accidents (DBAs)

- **Transient Overpower (TOP).** This accident was selected to represent and bound potential events that result from the addition of reactivity events, such as the uncontrolled rotation of one CD to the mechanical stop position resulting in insertion of the total excess reactivity at the highest possible rate.
- **Loss of Heat Sink (LOHS).** This accident was selected to represent and bound potential events that result from the undercooling or decrease in heat removal faults that result in the loss of the capability to remove reactor heat, such as the loss of active heat removal from the reactor core to the ultimate heat sink.
- **Loss of Flow (LOF).** This accident was selected to represent and bound potential events due to the loss of primary flow, such as from IHX failure and leakage of secondary coolant into the PCS.
- **Loss of Power (LOP).** This accident was selected to represent and bound potential events due to the loss of offsite power (LOOP)
- **Seismic Event ($g \leq SSE$).** This accident was selected to represent and bound potential events due to a seismic event with a magnitude \leq the safe shutdown earthquake (SSE).
- **Loss of Coolant Accident (LOCA).** This accident was selected to represent and bound potential events due to a decrease in reactor coolant inventory, such as from a break of the low-elevation components (downcomer, lower plenum).

Quantitative DBA analysis performed assuming only the PASSIVE safety related (SR)-SSCs are available



Reactivity Control:

Non-SR (NSR) Reactor Protection System (RPS) and Scram – NOT Available

SR Passive Inherent Reactivity Feedback (IRF) – Available

Heat Removal:

NSR Active Heat Removal – NOT Available

SR Passive Conduction and Convection SSCs – Available

Quantitative DBA Evaluation - TOP Thermal-Hydraulic (T-H) Results

Initiating Event:

- Reactivity insertion (0.40) due to a single CD movement
- Freq = Unlikely



Available SSCs performing FSFs:

- Active RPS trip of CDs assumed unavailable
- Active heat removal assumed unavailable
- Reactivity control is provided exclusively by IRF.
- Core heat removal is provided exclusively by passive conduction/convection to ultimate heat sink.

Table 15-2. MARVEL T-H acceptance criteria.

Acceptance Criteria	Design Basis Events			
	Normal Operation	Anticipated Events	Unlikely Events	Extremely Unlikely Events
1	Peak fuel centerline temperature <900°C			
2	Peak clad temperature <764°C			
3	Bulk coolant <530°C			
4		Bulk coolant <650°C		
5			Bulk coolant <704°C	
6	Core remains coolable			

Hot spot safety margins for TOP @ hot full power without active heat removal. (Larger value = more margin)




- **Despite active FSF failures, passive IRF and heat removal ensure T-H acceptance criteria are met, no core damage occurs, and no radiological release occurs.**
- **Confirms the qualitative hazard evaluation assumptions!**

Conclusions:

As demonstrated in the DSA, the proposed MARVEL design:


- Accommodates various beyond-design-basis accident initiators without producing conditions that might lead to a severe accident.
- The passive inherent negative reactivity feedback, hydraulic, and thermal performance characteristics of the MARVEL design provide margin in many beyond-design-basis sequences to limit accident consequences without activation of active engineered systems or operator actions.
- These same passive characteristics have been shown in the PDSA to provide margin for operational and safety basis events.



The MARVEL hazard evaluation meets the intent of NEI-18-04 as follows:

- ***Risk-Informed***: Although a PRA was not performed, the MARVEL hazard evaluation provides a qualitative approach for risk assessment that provides reasonable assurance of protection of the public and worker. Confirmed by quantitative analysis!!
- ***Performance-Based***: The MARVEL hazard evaluation provides a simplified analysis of the performance requirements for the passive SSCs performing the FSFs necessary for preventing IEs from progressing into sequences that could result in core damage and radiological or non-radiological releases.

Thank-you



MRP Microreactor
Program



Questions?